

Отчет о суточных параметрах ГВС
(01.11.2023 0:00:00 - 30.11.2023 0:00:00)

Объект: Пермь г, Ласьвинская ул, д. 62А (ООО "УК "ЖКХ Кировский")
Прибор: Карат-30X Заводской номер: 00461021
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

| Дата | t1 | t2 | dt | V1 | V2 | M1 | M2 | P1 | P2 | Q1 | Q2 | Q3 | Траб | NS | gNSCode |
|------------|-------|-------|-------|---------|---------|---------|---------|---------|---------|--------|--------|--------|-------|----|----------|
| | °C | °C | °C | м3 | м3 | т | т | кгс/см2 | кгс/см2 | Гкал | Гкал | Гкал | ч | | |
| 01.11.2023 | 62.79 | 53.63 | 9.12 | 29.271 | 26.152 | 28.743 | 25.803 | 4.49 | 4.13 | 1.661 | 1.254 | 0.407 | 24.0 | * | HC G |
| 02.11.2023 | 63.73 | 54.32 | 9.41 | 29.206 | 26.187 | 28.664 | 25.829 | 4.49 | 4.14 | 1.683 | 1.273 | 0.410 | 24.0 | * | HC G |
| 03.11.2023 | 62.95 | 53.88 | 9.11 | 29.209 | 26.197 | 28.679 | 25.844 | 4.50 | 4.15 | 1.662 | 1.263 | 0.399 | 24.0 | * | HC G |
| 04.11.2023 | 63.53 | 54.03 | 9.44 | 29.675 | 26.064 | 29.128 | 25.711 | 4.47 | 4.13 | 1.705 | 1.260 | 0.444 | 24.0 | * | HC G |
| 05.11.2023 | 63.19 | 53.85 | 9.27 | 29.605 | 26.166 | 29.064 | 25.814 | 4.47 | 4.12 | 1.691 | 1.261 | 0.430 | 24.0 | * | HC G |
| 06.11.2023 | 62.93 | 53.77 | 9.18 | 30.186 | 26.040 | 29.639 | 25.691 | 4.47 | 4.12 | 1.717 | 1.252 | 0.464 | 24.0 | * | HC G |
| 07.11.2023 | 63.88 | 54.51 | 9.37 | 29.582 | 26.583 | 29.031 | 26.217 | 4.48 | 4.13 | 1.709 | 1.298 | 0.411 | 24.0 | * | HC G |
| 08.11.2023 | 63.86 | 54.55 | 9.33 | 29.238 | 26.690 | 28.694 | 26.322 | 4.49 | 4.13 | 1.689 | 1.304 | 0.385 | 24.0 | * | HC G |
| 09.11.2023 | 63.78 | 54.51 | 9.28 | 29.388 | 26.582 | 28.842 | 26.216 | 4.48 | 4.12 | 1.695 | 1.298 | 0.397 | 24.0 | * | HC G |
| 10.11.2023 | 63.98 | 54.67 | 9.33 | 29.463 | 26.520 | 28.913 | 26.152 | 4.48 | 4.13 | 1.705 | 1.299 | 0.407 | 24.0 | * | HC G |
| 11.11.2023 | 63.55 | 54.20 | 9.37 | 29.263 | 26.320 | 28.723 | 25.961 | 4.48 | 4.13 | 1.681 | 1.277 | 0.405 | 24.0 | * | HC G |
| 12.11.2023 | 63.03 | 53.87 | 9.19 | 30.172 | 25.990 | 29.624 | 25.640 | 4.46 | 4.11 | 1.719 | 1.253 | 0.466 | 24.0 | * | HC G |
| 13.11.2023 | 63.23 | 54.05 | 9.20 | 29.419 | 26.486 | 28.881 | 26.127 | 4.47 | 4.11 | 1.682 | 1.281 | 0.401 | 24.0 | * | HC G |
| 14.11.2023 | 63.79 | 54.43 | 9.37 | 29.641 | 26.105 | 29.090 | 25.746 | 4.48 | 4.12 | 1.710 | 1.272 | 0.438 | 24.0 | * | HC G |
| 15.11.2023 | 63.16 | 54.07 | 9.14 | 29.503 | 26.297 | 28.965 | 25.940 | 4.48 | 4.12 | 1.684 | 1.273 | 0.412 | 24.0 | * | HC G |
| 16.11.2023 | 62.32 | 52.86 | 11.18 | 21.260 | 16.251 | 20.882 | 16.039 | 4.50 | 4.28 | 1.197 | 0.767 | 0.429 | 24.0 | * | Vmin; HC |
| 17.11.2023 | 63.16 | 53.73 | 9.40 | 30.726 | 25.146 | 30.166 | 24.809 | 4.50 | 4.13 | 1.754 | 1.209 | 0.545 | 24.0 | | Ok |
| 18.11.2023 | 60.83 | 51.79 | 9.01 | 30.854 | 24.363 | 30.329 | 24.060 | 4.49 | 4.14 | 1.693 | 1.125 | 0.568 | 24.0 | | Ok |
| 19.11.2023 | 59.90 | 51.04 | 8.73 | 31.824 | 24.075 | 31.298 | 23.784 | 4.48 | 4.12 | 1.718 | 1.095 | 0.623 | 24.0 | | Ok |
| 20.11.2023 | 60.04 | 50.94 | 9.15 | 21.249 | 16.489 | 20.895 | 16.290 | 3.24 | 3.00 | 1.150 | 0.748 | 0.402 | 24.0 | * | HC G; H |
| 21.11.2023 | 60.79 | 51.61 | 9.11 | 31.276 | 25.167 | 30.745 | 24.856 | 4.49 | 4.17 | 1.715 | 1.158 | 0.557 | 24.0 | | Ok |
| 22.11.2023 | 61.26 | 51.82 | 9.38 | 30.597 | 24.647 | 30.070 | 24.340 | 4.51 | 4.20 | 1.691 | 1.139 | 0.552 | 24.0 | | Ok |
| 23.11.2023 | 59.29 | 50.51 | 8.77 | 30.628 | 24.127 | 30.132 | 23.841 | 4.51 | 4.20 | 1.636 | 1.085 | 0.551 | 24.0 | | Ok |
| 24.11.2023 | 57.27 | 49.09 | 8.20 | 30.080 | 23.807 | 29.624 | 23.541 | 4.51 | 4.20 | 1.548 | 1.038 | 0.510 | 24.0 | | Ok |
| 25.11.2023 | 58.45 | 49.57 | 8.67 | 30.600 | 23.159 | 30.117 | 22.895 | 4.51 | 4.21 | 1.609 | 1.020 | 0.589 | 24.0 | | Ok |
| 26.11.2023 | 61.92 | 51.88 | 9.77 | 30.366 | 23.122 | 29.832 | 22.833 | 4.49 | 4.19 | 1.698 | 1.070 | 0.628 | 24.0 | | Ok |
| 27.11.2023 | 63.78 | 53.37 | 10.39 | 29.217 | 23.530 | 28.674 | 23.219 | 4.50 | 4.19 | 1.685 | 1.123 | 0.563 | 24.0 | | Ok |
| 28.11.2023 | 63.00 | 52.88 | 10.08 | 29.331 | 23.313 | 28.798 | 23.011 | 4.50 | 4.19 | 1.670 | 1.101 | 0.569 | 24.0 | | Ok |
| 29.11.2023 | 63.28 | 53.14 | 10.13 | 29.471 | 23.145 | 28.931 | 22.842 | 4.49 | 4.18 | 1.686 | 1.099 | 0.587 | 24.0 | | Ok |
| 30.11.2023 | 62.20 | 52.29 | 9.90 | 29.065 | 23.279 | 28.550 | 22.983 | 4.49 | 4.17 | 1.633 | 1.087 | 0.546 | 24.0 | | Ok |
| Средние: | 62.29 | 52.96 | 9.36 | --- | --- | --- | --- | 4.45 | 4.11 | --- | --- | --- | --- | | |
| Итого: | --- | --- | --- | 879.365 | 737.999 | 863.725 | 728.356 | --- | --- | 49.475 | 34.981 | 14.494 | 720.0 | | |

| Дата | V1 | V2 | M1 | M2 | Q1 | Q2 | Q3 | Траб |
|------------|-----------|-----------|-----------|-----------|----------|---------|---------|---------|
| | м3 | м3 | т | т | Гкал | Гкал | Гкал | ч |
| 31.10.2023 | 22798.130 | 18564.420 | 22415.880 | 18336.190 | 1238.628 | 849.472 | 389.156 | 19785.1 |
| 30.11.2023 | 23677.490 | 19302.420 | 23279.610 | 19064.550 | 1288.103 | 884.453 | 403.650 | 20505.1 |
| Итого: | 879.360 | 738.000 | 863.730 | 728.360 | 49.475 | 34.981 | 14.494 | 720.0 |

Представитель абонента

Представитель энергоснабжающей организации