

Отчет о суточных параметрах ГВС  
(01.02.2024 0:00:00 - 29.02.2024 0:00:00)

Объект: Пермь г, Ласьвинская ул, д. 62А (ООО "УК "ЖКХ Кировский")  
Прибор: Карат-30X Заводской номер: 00461021  
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

| Дата       | t1    | t2    | dt    | V1      | V2      | M1      | M2      | P1      | P2      | Q1     | Q2     | Q3     | Траб  | NS | gNSCode  |
|------------|-------|-------|-------|---------|---------|---------|---------|---------|---------|--------|--------|--------|-------|----|----------|
|            | °C    | °C    | °C    | м3      | м3      | т       | т       | кгс/см2 | кгс/см2 | Гкал   | Гкал   | Гкал   | ч     |    |          |
| 01.02.2024 | 66.58 | 55.91 | 10.68 | 30.007  | 24.199  | 29.403  | 23.848  | 4.47    | 4.08    | 1.811  | 1.214  | 0.597  | 24.0  |    | Ok       |
| 02.02.2024 | 66.16 | 55.58 | 10.58 | 29.719  | 24.262  | 29.128  | 23.914  | 4.48    | 4.08    | 1.781  | 1.209  | 0.572  | 24.0  |    | Ok       |
| 03.02.2024 | 64.84 | 54.58 | 10.24 | 30.303  | 23.663  | 29.723  | 23.336  | 4.49    | 4.10    | 1.779  | 1.157  | 0.622  | 24.0  |    | Ok       |
| 04.02.2024 | 64.39 | 54.20 | 10.09 | 30.709  | 23.455  | 30.129  | 23.135  | 4.48    | 4.09    | 1.789  | 1.138  | 0.651  | 24.0  |    | Ok       |
| 05.02.2024 | 65.29 | 54.78 | 10.47 | 29.893  | 23.851  | 29.313  | 23.519  | 4.49    | 4.09    | 1.767  | 1.170  | 0.597  | 24.0  |    | Ok       |
| 06.02.2024 | 66.24 | 55.51 | 10.67 | 28.589  | 23.909  | 28.019  | 23.567  | 4.50    | 4.10    | 1.716  | 1.190  | 0.526  | 24.0  |    | Ok       |
| 07.02.2024 | 67.29 | 56.11 | 11.18 | 27.415  | 23.827  | 26.853  | 23.480  | 4.50    | 4.10    | 1.673  | 1.200  | 0.473  | 24.0  |    | Ok       |
| 08.02.2024 | 64.95 | 54.50 | 10.52 | 27.460  | 23.607  | 26.933  | 23.282  | 4.50    | 4.09    | 1.614  | 1.152  | 0.463  | 24.0  | *  | HC G     |
| 09.02.2024 | 61.68 | 52.21 | 9.51  | 27.438  | 23.455  | 26.959  | 23.158  | 4.49    | 4.08    | 1.528  | 1.093  | 0.435  | 24.0  | *  | HC G     |
| 10.02.2024 | 60.33 | 51.03 | 9.24  | 27.194  | 23.297  | 26.739  | 23.015  | 4.49    | 4.08    | 1.479  | 1.059  | 0.420  | 24.0  | *  | HC G     |
| 11.02.2024 | 60.09 | 50.82 | 9.21  | 27.863  | 23.012  | 27.400  | 22.736  | 4.47    | 4.06    | 1.509  | 1.041  | 0.468  | 24.0  |    | Ok       |
| 12.02.2024 | 60.37 | 51.24 | 9.09  | 27.489  | 23.751  | 27.029  | 23.461  | 4.46    | 4.05    | 1.496  | 1.084  | 0.412  | 24.0  | *  | HC G     |
| 13.02.2024 | 60.41 | 51.39 | 9.00  | 28.219  | 23.729  | 27.746  | 23.438  | 4.47    | 4.06    | 1.537  | 1.087  | 0.450  | 24.0  | *  | HC G     |
| 14.02.2024 | 59.73 | 50.78 | 8.91  | 27.867  | 23.806  | 27.409  | 23.521  | 4.45    | 4.04    | 1.500  | 1.076  | 0.424  | 24.0  | *  | HC G     |
| 15.02.2024 | 60.05 | 50.99 | 8.98  | 27.916  | 23.765  | 27.453  | 23.478  | 4.44    | 4.03    | 1.511  | 1.079  | 0.432  | 24.0  |    | Ok       |
| 16.02.2024 | 60.04 | 51.04 | 8.93  | 27.918  | 23.735  | 27.455  | 23.448  | 4.44    | 4.02    | 1.511  | 1.079  | 0.432  | 24.0  | *  | HC G     |
| 17.02.2024 | 59.82 | 50.89 | 8.86  | 27.957  | 23.537  | 27.497  | 23.254  | 4.45    | 4.04    | 1.507  | 1.067  | 0.441  | 24.0  | *  | HC G     |
| 18.02.2024 | 60.24 | 51.16 | 8.99  | 28.774  | 23.271  | 28.294  | 22.988  | 4.45    | 4.05    | 1.563  | 1.061  | 0.502  | 24.0  | *  | HC G     |
| 19.02.2024 | 62.15 | 52.71 | 9.42  | 27.600  | 24.195  | 27.112  | 23.883  | 4.47    | 4.06    | 1.549  | 1.139  | 0.410  | 24.0  | *  | HC G     |
| 20.02.2024 | 62.09 | 52.83 | 9.25  | 27.684  | 24.262  | 27.195  | 23.948  | 4.46    | 4.05    | 1.552  | 1.145  | 0.407  | 24.0  | *  | HC G     |
| 21.02.2024 | 61.36 | 52.30 | 9.06  | 27.921  | 23.999  | 27.439  | 23.695  | 4.45    | 4.05    | 1.546  | 1.120  | 0.426  | 24.0  |    | Ok       |
| 22.02.2024 | 60.99 | 52.06 | 8.93  | 27.725  | 23.922  | 27.252  | 23.621  | 4.46    | 4.05    | 1.526  | 1.111  | 0.414  | 24.0  | *  | HC G     |
| 23.02.2024 | 60.81 | 51.73 | 9.04  | 27.922  | 23.467  | 27.448  | 23.175  | 4.46    | 4.06    | 1.532  | 1.082  | 0.449  | 24.0  | *  | HC G     |
| 24.02.2024 | 60.70 | 51.64 | 9.02  | 27.052  | 23.652  | 26.594  | 23.359  | 4.47    | 4.06    | 1.481  | 1.089  | 0.392  | 24.0  |    | Ok       |
| 25.02.2024 | 62.68 | 52.93 | 9.61  | 27.866  | 23.171  | 27.365  | 22.870  | 4.45    | 4.05    | 1.578  | 1.096  | 0.482  | 24.0  |    | Ok       |
| 26.02.2024 | 64.15 | 54.15 | 10.01 | 25.887  | 22.836  | 25.401  | 22.525  | 4.52    | 4.04    | 1.502  | 1.107  | 0.396  | 24.0  | *  | HC V; HC |
| 27.02.2024 | 64.96 | 54.55 | 10.33 | 26.838  | 23.588  | 26.322  | 23.262  | 4.47    | 4.05    | 1.578  | 1.152  | 0.426  | 24.0  | *  | HC G     |
| 28.02.2024 | 66.14 | 55.39 | 10.71 | 26.829  | 23.426  | 26.296  | 23.093  | 4.47    | 4.05    | 1.608  | 1.163  | 0.444  | 24.0  |    | Ok       |
| 29.02.2024 | 66.72 | 55.75 | 10.95 | 27.164  | 23.138  | 26.616  | 22.805  | 4.47    | 4.05    | 1.643  | 1.157  | 0.486  | 24.0  |    | Ok       |
| Средние:   | 62.80 | 53.06 | 9.71  | ---     | ---     | ---     | ---     | 4.47    | 4.06    | ---    | ---    | ---    | ---   |    |          |
| Итого:     | ---   | ---   | ---   | 813.218 | 685.787 | 798.521 | 676.814 | ---     | ---     | 46.165 | 32.518 | 13.647 | 696.0 |    |          |

| Дата       | V1        | V2        | M1        | M2        | Q1       | Q2      | Q3      | Траб    |
|------------|-----------|-----------|-----------|-----------|----------|---------|---------|---------|
|            | м3        | м3        | т         | т         | Гкал     | Гкал    | Гкал    | ч       |
| 31.01.2024 | 25508.880 | 20731.310 | 25079.370 | 20475.610 | 1389.406 | 950.487 | 438.919 | 21993.1 |
| 29.02.2024 | 26322.100 | 21417.100 | 25877.890 | 21152.420 | 1435.571 | 983.005 | 452.566 | 22689.1 |
| Итого:     | 813.220   | 685.790   | 798.520   | 676.810   | 46.165   | 32.518  | 13.647  | 696.0   |

Представитель абонента

Представитель энергоснабжающей организации