

Отчет о суточных параметрах ГВС
(01.01.2025 0:00:00 - 31.01.2025 0:00:00)

Объект: Пермский край, Пермь г, Глазовская ул, д. 9 (УК "ЖКХ "Кировский")
Прибор: Карат-30X Заводской номер: 13091721
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

| Дата | t1 | V1 | M1 | P1 | Q1 | Траб | NS | gNSCode |
|------------|-------|---------|---------|---------|--------|-------|----|---------|
| | °C | м3 | т | кгс/см2 | Гкал | ч | | |
| 01.01.2025 | 61.51 | 11.540 | 11.340 | 5.24 | 0.641 | 24.0 | | Ok |
| 02.01.2025 | 62.08 | 14.150 | 13.900 | 5.37 | 0.794 | 24.0 | | Ok |
| 03.01.2025 | 59.08 | 14.010 | 13.785 | 5.22 | 0.746 | 24.0 | | Ok |
| 04.01.2025 | 62.44 | 13.110 | 12.876 | 5.22 | 0.740 | 24.0 | | Ok |
| 05.01.2025 | 59.13 | 14.790 | 14.552 | 5.22 | 0.788 | 24.0 | | Ok |
| 06.01.2025 | 62.10 | 13.400 | 13.163 | 5.21 | 0.752 | 24.0 | | Ok |
| 07.01.2025 | 62.30 | 16.330 | 16.040 | 5.22 | 0.919 | 24.0 | | Ok |
| 08.01.2025 | 62.02 | 16.500 | 16.209 | 5.21 | 0.924 | 24.0 | | Ok |
| 09.01.2025 | 57.75 | 15.400 | 15.163 | 5.22 | 0.800 | 24.0 | | Ok |
| 10.01.2025 | 59.28 | 15.050 | 14.807 | 5.21 | 0.804 | 24.0 | | Ok |
| 11.01.2025 | 60.15 | 14.900 | 14.652 | 5.21 | 0.808 | 24.0 | | Ok |
| 12.01.2025 | 59.56 | 17.560 | 17.274 | 5.21 | 0.942 | 24.0 | | Ok |
| 13.01.2025 | 62.25 | 15.570 | 15.294 | 5.21 | 0.876 | 24.0 | | Ok |
| 14.01.2025 | 62.00 | 15.320 | 15.050 | 5.20 | 0.858 | 24.0 | | Ok |
| 15.01.2025 | 62.39 | 15.290 | 15.018 | 5.20 | 0.862 | 24.0 | | Ok |
| 16.01.2025 | 62.22 | 14.370 | 14.115 | 5.21 | 0.808 | 24.0 | | Ok |
| 17.01.2025 | 61.85 | 12.820 | 12.595 | 5.21 | 0.716 | 24.0 | | Ok |
| 18.01.2025 | 62.09 | 14.300 | 14.048 | 5.21 | 0.802 | 24.0 | | Ok |
| 19.01.2025 | 61.46 | 16.210 | 15.929 | 5.23 | 0.899 | 24.0 | | Ok |
| 20.01.2025 | 61.27 | 14.690 | 14.437 | 5.21 | 0.812 | 24.0 | | Ok |
| 21.01.2025 | 61.96 | 14.980 | 14.717 | 5.20 | 0.838 | 24.0 | | Ok |
| 22.01.2025 | 61.88 | 14.070 | 13.823 | 5.20 | 0.786 | 24.0 | | Ok |
| 23.01.2025 | 61.54 | 15.300 | 15.035 | 5.20 | 0.850 | 24.0 | | Ok |
| 24.01.2025 | 61.95 | 15.250 | 14.982 | 5.21 | 0.853 | 24.0 | | Ok |
| 25.01.2025 | 62.24 | 14.990 | 14.724 | 5.21 | 0.843 | 24.0 | | Ok |
| 26.01.2025 | 62.37 | 15.760 | 15.479 | 5.20 | 0.888 | 24.0 | | Ok |
| 27.01.2025 | 61.97 | 15.050 | 14.785 | 5.21 | 0.842 | 24.0 | | Ok |
| 28.01.2025 | 61.68 | 17.010 | 16.714 | 5.22 | 0.947 | 24.0 | | Ok |
| 29.01.2025 | 61.93 | 15.170 | 14.904 | 5.21 | 0.849 | 24.0 | | Ok |
| 30.01.2025 | 59.30 | 11.390 | 11.201 | 4.11 | 0.608 | 24.0 | | Ok |
| 31.01.2025 | 60.75 | 15.560 | 15.297 | 5.21 | 0.853 | 24.0 | | Ok |
| Средние: | 61.31 | --- | --- | 5.18 | --- | --- | | |
| Итого: | --- | 459.840 | 451.910 | --- | 25.449 | 744.0 | | |

| Дата | V1 | M1 | Q1 | Траб |
|------------|-----------|-----------|---------|---------|
| | м3 | т | Гкал | ч |
| 31.12.2024 | 15915.130 | 15647.860 | 864.841 | 29436.3 |
| 31.01.2025 | 16374.970 | 16099.770 | 890.291 | 30180.3 |
| Итого: | 459.840 | 451.910 | 25.450 | 744.0 |

Представитель абонента

Представитель энергоснабжающей организации