

Отчет о суточных параметрах
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Танцорова ул, д. 33 (ООО "УК "ЖКХ Кировский")
Прибор: ТМК-Н30 (Н130) Заводской номер: 17487
Точка измерения: ТС1; Ресурс: ТС

Схема измерений: 1.3

| Дата | тсв1 | тсв2 | t1 | t2 | V1 | V2 | M1 | M2 | % | P1 | P2 | Qtv | txв | Pxв | TWork | QntHIP | NS | ISCodes: |
|------------|-------|-------|-------|-------|----------|----------|---------|---------|-------|---------|---------|---------|------|---------|-------|--------|----|----------|
| | °C | °C | °C | °C | м3 | м3 | т | т | т | кгс/см2 | кгс/см2 | Гкал | °C | кгс/см2 | ч | ч | | |
| 01.03.2025 | 75.24 | 47.51 | 75.21 | 47.50 | 195.531 | 195.191 | 190.64 | 193.16 | -1.31 | 5.62 | 4.39 | 5.293 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 02.03.2025 | 72.45 | 46.03 | 72.46 | 46.03 | 194.221 | 193.971 | 189.68 | 192.08 | -1.25 | 5.45 | 4.24 | 5.018 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 03.03.2025 | 74.74 | 47.51 | 74.75 | 47.51 | 199.511 | 199.211 | 194.58 | 197.14 | -1.31 | 5.69 | 4.41 | 5.304 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 04.03.2025 | 77.00 | 48.36 | 76.97 | 48.35 | 198.911 | 198.471 | 193.73 | 196.33 | -1.34 | 5.67 | 4.40 | 5.554 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 05.03.2025 | 78.10 | 48.25 | 78.10 | 48.23 | 193.871 | 193.331 | 188.69 | 191.26 | -1.35 | 5.53 | 4.33 | 5.640 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 06.03.2025 | 75.95 | 48.02 | 75.98 | 48.03 | 196.831 | 196.481 | 191.82 | 194.39 | -1.33 | 5.56 | 4.32 | 5.364 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 07.03.2025 | 76.44 | 48.53 | 76.47 | 48.54 | 201.471 | 201.101 | 196.29 | 198.92 | -1.33 | 5.63 | 4.33 | 5.487 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 08.03.2025 | 77.95 | 49.07 | 77.92 | 49.04 | 201.161 | 200.671 | 195.80 | 198.44 | -1.34 | 5.61 | 4.31 | 5.664 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 09.03.2025 | 78.46 | 48.61 | 78.52 | 48.63 | 193.021 | 192.371 | 187.81 | 190.27 | -1.30 | 5.45 | 4.26 | 5.614 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 10.03.2025 | 73.60 | 47.42 | 73.59 | 47.42 | 199.911 | 199.561 | 195.10 | 197.49 | -1.22 | 5.48 | 4.20 | 5.113 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 11.03.2025 | 71.40 | 46.19 | 71.35 | 46.15 | 196.621 | 196.401 | 192.14 | 194.47 | -1.20 | 5.44 | 4.19 | 4.850 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 12.03.2025 | 65.53 | 43.17 | 65.54 | 43.17 | 191.641 | 191.701 | 187.91 | 190.07 | -1.14 | 5.50 | 4.31 | 4.207 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 13.03.2025 | 65.25 | 43.24 | 65.26 | 43.25 | 193.131 | 193.251 | 189.40 | 191.60 | -1.15 | 5.55 | 4.35 | 4.174 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 14.03.2025 | 65.55 | 43.74 | 65.55 | 43.74 | 199.171 | 199.261 | 195.29 | 197.52 | -1.13 | 5.60 | 4.32 | 4.265 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 15.03.2025 | 55.79 | 38.80 | 54.59 | 38.25 | 168.171 | 168.581 | 165.69 | 167.42 | -1.04 | 3.49 | 2.56 | 2.807 | 5.00 | 5.00 | 24.0 | 23.2 | * | 7,A,B |
| 16.03.2025 | 68.26 | 41.05 | 66.12 | 38.05 | 121.950 | 121.510 | 119.39 | 120.57 | -0.98 | 5.60 | 5.00 | 3.251 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 17.03.2025 | 63.56 | 37.50 | 62.79 | 34.13 | 110.970 | 110.660 | 108.93 | 109.96 | -0.94 | 5.56 | 5.03 | 2.839 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 18.03.2025 | 69.62 | 44.75 | 69.45 | 44.64 | 192.661 | 191.961 | 188.47 | 190.19 | -0.91 | 5.30 | 4.11 | 4.693 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 19.03.2025 | 73.69 | 47.16 | 73.71 | 47.15 | 198.451 | 197.701 | 193.67 | 195.67 | -1.03 | 5.35 | 4.09 | 5.142 | 5.00 | 5.00 | 24.0 | 24.0 | * | A |
| 20.03.2025 | 71.56 | 46.09 | 71.55 | 46.10 | 194.201 | 195.931 | 189.76 | 194.01 | -2.21 | 5.41 | 4.20 | 4.837 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 21.03.2025 | 70.19 | 45.17 | 70.23 | 45.17 | 191.511 | 196.651 | 187.29 | 194.80 | -3.93 | 5.35 | 4.17 | 4.691 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 22.03.2025 | 69.78 | 45.26 | 69.81 | 45.27 | 195.811 | 201.351 | 191.54 | 199.45 | -4.05 | 5.45 | 4.22 | 4.703 | 5.00 | 5.00 | 24.0 | 24.0 | * | B |
| 23.03.2025 | 67.28 | 43.94 | 67.30 | 43.94 | 189.731 | 195.281 | 185.85 | 193.55 | -4.06 | 5.29 | 4.13 | 4.344 | 5.00 | 5.00 | 24.0 | 24.0 | * | B |
| 24.03.2025 | 65.22 | 43.49 | 65.23 | 43.48 | 197.011 | 202.911 | 193.21 | 201.15 | -4.03 | 5.37 | 4.12 | 4.204 | 5.00 | 5.00 | 24.0 | 24.0 | * | B |
| 25.03.2025 | 65.75 | 44.27 | 65.73 | 44.22 | 202.611 | 208.621 | 198.64 | 206.74 | -4.00 | 5.46 | 4.14 | 4.271 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 26.03.2025 | 65.32 | 44.41 | 65.32 | 44.41 | 206.411 | 212.471 | 202.42 | 210.54 | -3.94 | 5.44 | 4.07 | 4.239 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 27.03.2025 | 64.10 | 43.83 | 64.11 | 43.83 | 204.781 | 211.071 | 200.96 | 209.21 | -4.03 | 5.50 | 4.14 | 4.079 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 28.03.2025 | 63.93 | 44.31 | 63.94 | 44.29 | 212.081 | 218.471 | 208.14 | 216.50 | -3.94 | 5.56 | 4.11 | 4.090 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 29.03.2025 | 63.82 | 43.82 | 63.84 | 43.81 | 203.471 | 209.471 | 199.70 | 207.63 | -3.89 | 5.39 | 4.06 | 4.001 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 30.03.2025 | 64.01 | 44.04 | 64.03 | 44.02 | 205.931 | 212.061 | 202.09 | 210.17 | -3.92 | 5.40 | 4.04 | 4.041 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| 31.03.2025 | 64.85 | 45.67 | 64.81 | 45.58 | 226.301 | 233.241 | 221.98 | 231.00 | -3.98 | 5.65 | 4.00 | 4.265 | 5.00 | 5.00 | 24.0 | 24.0 | * | A,B |
| Средние: | 69.50 | 45.14 | 69.36 | 44.90 | --- | --- | --- | --- | -2.21 | 5.43 | 4.21 | --- | 5.00 | 5.00 | --- | --- | | |
| Итого: | --- | --- | --- | --- | 5977.061 | 6038.921 | 5846.61 | 5981.70 | --- | --- | --- | 142.042 | --- | --- | 744.0 | 743.2 | | |

| Дата | V1 | V2 | M1 | M2 | Qtv | TWork | QntHIP |
|------------|-----------|-----------|-----------|-----------|----------|---------|---------|
| | м3 | м3 | т | т | Гкал | ч | ч |
| 28.02.2025 | 113829.45 | 113444.95 | 110828.63 | 112304.91 | 3348.054 | 30516.5 | 15613.1 |
| 31.03.2025 | 119806.52 | 119483.88 | 116675.23 | 118286.62 | 3490.096 | 31260.5 | 16356.3 |
| Итого: | 5977.06 | 6038.92 | 5846.61 | 5981.70 | 142.042 | 744.0 | 743.2 |

Представитель абонента

Представитель энергоснабжающей организации