

Отчет о суточных параметрах  
(01.04.2025 0:00:00 - 30.04.2025 0:00:00)

Объект: Пермский край, Пермь г, Воронежская ул, д. 19 (УК "ЖКХ Кировский")  
Прибор: ТСРВ-033(034) Заводской номер: 906134  
Точка измерения: ТС1; Ресурс: ТС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	t2 °C	dt °C	m1 т	m2 т	%	W4 ГКал	W5 ГКал	W6 ГКал	Тнар ч	Тпр ч	NS
	°C	°C	°C	т	т		ГКал	ГКал	ГКал	ч	ч	
01.04.2025	69.10	41.54	27.56	86.42	84.85	1.83	2.39	2.39	2.39	24.00	0.00	
02.04.2025	69.31	41.21	28.10	84.31	82.70	1.93	2.37	2.37	2.37	24.00	0.00	
03.04.2025	68.37	39.55	28.82	78.21	76.65	2.00	2.26	2.26	2.26	24.00	0.00	
04.04.2025	68.31	38.86	29.45	76.80	75.17	2.15	2.27	2.27	2.27	24.00	0.00	
05.04.2025	71.17	41.17	30.00	81.73	80.13	1.98	2.46	2.46	2.46	24.00	0.00	
06.04.2025	68.55	38.22	30.33	78.69	77.10	2.05	2.39	2.39	2.39	24.00	0.00	
07.04.2025	68.60	39.48	29.12	78.01	76.43	2.05	2.28	2.28	2.28	24.00	0.00	
08.04.2025	68.52	39.51	29.01	78.70	77.15	1.99	2.29	2.29	2.29	24.00	0.00	
09.04.2025	68.35	39.90	28.45	78.18	76.75	1.85	2.23	2.23	2.23	24.00	0.00	
10.04.2025	68.48	38.57	29.91	74.41	72.94	1.99	2.23	2.23	2.23	24.00	0.00	
11.04.2025	67.75	38.45	29.30	71.87	70.33	2.17	2.11	2.11	2.11	24.00	0.00	
12.04.2025	68.28	38.26	30.02	73.23	71.71	2.10	2.20	2.20	2.20	24.00	0.00	
13.04.2025	68.21	38.00	30.21	74.50	72.79	2.32	2.25	2.25	2.25	24.00	0.00	
14.04.2025	68.26	39.26	29.00	79.63	77.91	2.18	2.31	2.31	2.31	24.00	0.00	
15.04.2025	68.34	39.41	28.93	77.49	75.92	2.05	2.25	2.25	2.25	24.00	0.00	
16.04.2025	68.65	40.02	28.63	77.22	75.63	2.08	2.21	2.21	2.21	24.00	0.00	
17.04.2025	68.22	38.36	29.86	76.41	74.89	2.01	2.28	2.28	2.28	24.00	0.00	
18.04.2025	68.54	40.22	28.32	79.53	78.00	1.94	2.26	2.26	2.26	24.00	0.00	
19.04.2025	68.76	40.53	28.23	81.12	79.62	1.87	2.29	2.29	2.29	24.00	0.00	
20.04.2025	68.60	40.96	27.64	79.23	77.73	1.92	2.19	2.19	2.19	24.00	0.00	
21.04.2025	68.24	39.61	28.63	73.21	71.74	2.04	2.10	2.10	2.10	24.00	0.00	
22.04.2025	68.36	40.34	28.02	76.85	75.36	1.96	2.16	2.16	2.16	24.00	0.00	
23.04.2025	68.17	40.30	27.87	80.27	78.76	1.89	2.24	2.24	2.24	24.00	0.00	
24.04.2025	68.62	40.55	28.07	76.93	75.45	1.95	2.16	2.16	2.16	24.00	0.00	
25.04.2025	68.06	39.66	28.40	70.93	69.45	2.11	2.02	2.02	2.02	24.00	0.00	
26.04.2025	68.56	39.96	28.60	71.14	69.64	2.13	2.04	2.04	2.04	24.00	0.00	
27.04.2025	67.86	38.52	29.34	72.72	71.26	2.03	2.14	2.14	2.14	24.00	0.00	
28.04.2025	67.08	37.84	29.24	73.11	71.55	2.16	2.14	2.14	2.14	24.00	0.00	
29.04.2025	69.50	39.88	29.62	78.15	76.58	2.03	2.32	2.32	2.32	24.00	0.00	
30.04.2025	67.92	39.84	28.08	77.92	76.28	2.12	2.19	2.19	2.19	24.00	0.00	
Средние:	68.49	39.60	28.89	---	---	2.03	---	---	---	---	---	
Итого:	---	---	---	2316.91	2270.45	---	67.01	67.01	67.01	720.00	0.00	

Дата	m1 т	m2 т	W4 ГКал	W5 ГКал	W6 ГКал	Тнар ч	Тпр ч
	т	т	ГКал	ГКал	ГКал	ч	ч
31.03.2025	148326.30	130582.36	4574.69	4574.69	4574.69	54666.72	1288.15
30.04.2025	150643.21	132852.80	4641.70	4641.70	4641.70	55386.72	1288.15
Итого:	2316.91	2270.45	67.01	67.01	67.01	720.00	0.00

Представитель абонента

Представитель энергоснабжающей организации