

Отчет о суточных параметрах  
(01.12.2025 0:00:00 - 31.12.2025 0:00:00)

Объект: Пермский край, Пермь г, Волгодонская ул, д. 13 (ООО "УК "ЖКХ Кировский")  
Прибор: ЭЛТЕКО ТС555 Заводской номер: 10279  
Точка измерения: УУ1; Ресурс: ТС

Датчик температуры:  
Поддача: ВЗЛЕТ ТПС SN 1212013  
Обратка: ВЗЛЕТ ТПС SN 1211126  
Схема измерений: Пользовательская

| Дата       | t1     | t2     | V1      | V2      | M1      | M2      | Qтс    |
|------------|--------|--------|---------|---------|---------|---------|--------|
|            | град.С | град.С | м.куб   | м.куб   | т       | т       | Гкал   |
| 01.12.2025 | 66.92  | 43.25  | 61.40   | 60.39   | 60.16   | 59.86   | 1.426  |
| 02.12.2025 | 67.17  | 42.75  | 59.22   | 57.76   | 58.02   | 57.25   | 1.420  |
| 03.12.2025 | 67.90  | 43.53  | 62.02   | 61.06   | 60.74   | 60.51   | 1.482  |
| 04.12.2025 | 68.37  | 43.74  | 62.50   | 61.67   | 61.19   | 61.11   | 1.509  |
| 05.12.2025 | 69.28  | 44.20  | 63.06   | 62.32   | 61.71   | 61.74   | 1.549  |
| 06.12.2025 | 73.48  | 47.55  | 70.81   | 69.27   | 69.11   | 68.53   | 1.797  |
| 07.12.2025 | 83.64  | 53.23  | 78.22   | 76.39   | 75.88   | 75.37   | 2.284  |
| 08.12.2025 | 89.23  | 51.28  | 63.48   | 61.72   | 61.30   | 60.94   | 2.341  |
| 09.12.2025 | 96.74  | 53.05  | 64.02   | 62.01   | 61.52   | 61.19   | 2.700  |
| 10.12.2025 | 86.49  | 50.43  | 64.54   | 62.86   | 62.46   | 62.10   | 2.263  |
| 11.12.2025 | 80.63  | 46.83  | 59.57   | 57.57   | 57.90   | 56.97   | 1.960  |
| 12.12.2025 | 80.74  | 48.49  | 63.86   | 62.38   | 62.05   | 61.69   | 2.006  |
| 13.12.2025 | 74.21  | 45.68  | 61.44   | 60.24   | 59.94   | 59.64   | 1.714  |
| 14.12.2025 | 78.58  | 47.40  | 62.19   | 61.03   | 60.51   | 60.38   | 1.889  |
| 15.12.2025 | 87.00  | 51.71  | 66.61   | 64.94   | 64.46   | 64.12   | 2.283  |
| 16.12.2025 | 97.89  | 55.57  | 67.98   | 65.87   | 65.27   | 64.92   | 2.773  |
| 17.12.2025 | 101.13 | 58.55  | 73.38   | 70.83   | 70.29   | 69.70   | 3.006  |
| 18.12.2025 | 96.65  | 58.43  | 78.18   | 75.94   | 75.14   | 74.73   | 2.877  |
| 19.12.2025 | 90.16  | 56.04  | 77.17   | 75.16   | 74.52   | 74.07   | 2.546  |
| 20.12.2025 | 98.84  | 54.65  | 65.10   | 63.30   | 62.46   | 62.41   | 2.771  |
| 21.12.2025 | 96.71  | 57.74  | 76.95   | 74.55   | 73.95   | 73.39   | 2.876  |
| 22.12.2025 | 88.00  | 55.33  | 77.41   | 75.56   | 74.85   | 74.47   | 2.452  |
| 23.12.2025 | 92.18  | 53.67  | 66.51   | 64.73   | 64.14   | 63.86   | 2.460  |
| 24.12.2025 | 107.09 | 57.18  | 65.30   | 62.94   | 62.27   | 61.97   | 3.126  |
| 25.12.2025 | 113.27 | 59.99  | 68.24   | 65.28   | 64.74   | 64.20   | 3.466  |
| 26.12.2025 | 103.14 | 58.41  | 72.12   | 69.46   | 68.98   | 68.36   | 3.094  |
| 27.12.2025 | 92.92  | 54.08  | 68.90   | 66.79   | 66.40   | 65.87   | 2.590  |
| 28.12.2025 | 85.14  | 50.23  | 64.35   | 63.07   | 62.34   | 62.32   | 2.181  |
| 29.12.2025 | 93.63  | 55.40  | 71.99   | 69.76   | 69.33   | 68.76   | 2.663  |
| 30.12.2025 | 101.96 | 57.50  | 69.61   | 67.04   | 66.65   | 66.01   | 2.973  |
| 31.12.2025 | 97.97  | 56.99  | 71.85   | 69.56   | 68.98   | 68.50   | 2.834  |
| Средние:   | 87.97  | 52.03  | ---     | ---     | ---     | ---     | ---    |
| Итого:     | ---    | ---    | 2097.98 | 2041.45 | 2027.26 | 2014.94 | 73.311 |

| Дата       | V1       | V2       | M1       | M2       | Qтс      |
|------------|----------|----------|----------|----------|----------|
|            | м.куб    | м.куб    | т        | т        | Гкал     |
| 30.11.2025 | 57326.01 | 49619.50 | 55888.39 | 49148.79 | 1693.949 |
| 31.12.2025 | 59423.99 | 51660.95 | 57915.65 | 51163.73 | 1767.260 |
| Итого:     | 2097.98  | 2041.45  | 2027.26  | 2014.94  | 73.311   |

Представитель абонента

Представитель энергоснабжающей организации