

Отчет о суточных параметрах ГВС
(01.03.2026 0:00:00 - 31.03.2026 0:00:00)

Объект: Пермский край, Пермь г, Химградская ул, д. 3 (ООО "УК "ЖКХ Кировский")
Прибор: КМ-5/АТ-Т Заводской номер: 371026
Точка измерения: ТВ1; Ресурс: ГВС

Схема измерений: КМ-5-1

Дата	t1	t2	dt	V1	V2	V3	M1	M2	%	P1	P2	Qот	ta	Tr	NS
	°C	°C	°C	м3	м3	м3	т	т	т	атм	атм	Гкал	°C	ч	
01.03.2026	62.65	5.00	57.65	12.75	0.00	0.00	12.52	0.00	200.00	4.71	2.56	0.72	-60.00	24.00	
02.03.2026	59.56	5.00	54.56	9.33	0.00	0.00	9.18	0.00	200.00	5.03	2.56	0.50	-60.00	24.00	
03.03.2026	57.96	5.00	52.96	9.31	0.00	0.00	9.16	0.00	200.00	4.99	2.56	0.49	-60.00	24.00	
04.03.2026	58.43	5.00	53.43	12.12	0.00	0.00	11.93	0.00	200.00	5.16	2.56	0.64	-60.00	24.00	
05.03.2026	58.48	5.00	53.48	10.47	0.00	0.00	10.30	0.00	200.00	5.01	2.56	0.55	-60.00	24.00	
06.03.2026	58.15	5.00	53.15	9.95	0.00	0.00	9.80	0.00	200.00	5.04	2.56	0.52	-60.00	24.00	
07.03.2026	55.59	5.00	50.59	10.90	0.00	0.00	10.75	0.00	200.00	5.07	2.56	0.54	-60.00	24.00	
08.03.2026	54.95	5.00	49.95	12.78	0.00	0.00	12.60	0.00	200.00	5.08	2.56	0.63	-60.00	24.00	
09.03.2026	56.10	5.00	51.10	11.02	0.00	0.00	10.86	0.00	200.00	4.86	2.56	0.55	-60.00	24.00	
10.03.2026	60.97	5.00	55.97	10.42	0.00	0.00	10.24	0.00	200.00	4.88	2.56	0.57	-60.00	24.00	
11.03.2026	63.74	5.00	58.74	8.86	0.00	0.00	8.70	0.00	200.00	4.87	2.56	0.51	-60.00	24.00	
12.03.2026	63.61	5.00	58.61	9.32	0.00	0.00	9.15	0.00	200.00	4.82	2.56	0.54	-60.00	24.00	
13.03.2026	63.65	5.00	58.65	8.26	0.00	0.00	8.11	0.00	200.00	4.90	2.56	0.48	-60.00	24.00	
14.03.2026	63.67	5.00	58.67	9.55	0.00	0.00	9.38	0.00	200.00	4.62	2.56	0.55	-60.00	24.00	
15.03.2026	63.69	5.00	58.69	10.81	0.00	0.00	10.61	0.00	200.00	4.48	2.56	0.62	-60.00	24.00	
16.03.2026	63.59	5.00	58.59	9.46	0.00	0.00	9.29	0.00	200.00	4.71	2.56	0.54	-60.00	24.00	
17.03.2026	63.51	5.00	58.51	8.57	0.00	0.00	8.42	0.00	200.00	4.76	2.56	0.49	-60.00	24.00	
18.03.2026	63.50	5.00	58.50	11.84	0.00	0.00	11.63	0.00	200.00	4.64	2.56	0.68	-60.00	24.00	
19.03.2026	63.29	5.00	58.29	8.47	0.00	0.00	8.31	0.00	200.00	4.68	2.56	0.48	-60.00	24.00	
20.03.2026	63.31	5.00	58.31	8.79	0.00	0.00	8.63	0.00	200.00	4.86	2.56	0.50	-60.00	24.09	
21.03.2026	63.54	5.00	58.54	12.38	0.00	0.00	12.16	0.00	200.00	4.80	2.56	0.71	-60.00	24.00	
22.03.2026	63.62	5.00	58.62	10.94	0.00	0.00	10.74	0.00	200.00	4.55	2.56	0.63	-60.00	24.00	
23.03.2026	63.54	5.00	58.54	9.00	0.00	0.00	8.84	0.00	200.00	4.70	2.56	0.52	-60.00	24.00	
24.03.2026	63.52	5.00	58.52	9.96	0.00	0.00	9.78	0.00	200.00	4.84	2.56	0.57	-60.00	24.00	
25.03.2026	63.43	5.00	58.43	9.08	0.00	0.00	8.92	0.00	200.00	4.93	2.56	0.52	-60.00	23.99	
26.03.2026	63.37	5.00	58.37	9.71	0.00	0.00	9.53	0.00	200.00	4.94	2.56	0.56	-60.00	24.00	
27.03.2026	63.42	5.00	58.42	8.83	0.00	0.00	8.67	0.00	200.00	4.81	2.56	0.51	-60.00	24.00	
28.03.2026	62.72	5.00	57.72	0.65	0.00	0.00	0.64	0.00	200.00	5.60	2.55	0.04	-60.00	5.50	
29.03.2026	63.64	5.00	58.64	8.36	0.00	0.00	8.20	0.00	200.00	4.02	2.56	0.48	-60.00	14.34	
30.03.2026	63.49	5.00	58.49	9.08	0.00	0.00	8.91	0.00	200.00	4.68	2.56	0.52	-60.00	24.00	
31.03.2026	63.45	5.00	58.45	10.10	0.00	0.00	9.92	0.00	200.00	4.79	2.56	0.58	-60.00	24.00	
Средние:	61.81	5.00	56.81	---	---	---	---	---	200.00	4.83	2.56	---	-60.00	---	
Итого:	---	---	---	301.09	0.00	0.00	295.87	0.00	---	---	---	16.75	---	715.92	

Дата	V1	V2	V3	M1	M2	Qот	Tr
	м3	м3	м3	т	т	Гкал	ч
28.02.2026	581.06	0.00	0.00	570.71	0.00	32.88	1416.46
31.03.2026	882.15	0.00	0.00	866.58	0.00	49.63	2132.38
Итого:	301.09	0.00	0.00	295.87	0.00	16.75	715.92

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.03.2026 0:00:00 - 31.03.2026 0:00:00)

Объект: Пермский край, Пермь г, Химградская ул, д. 3 (ООО "УК "ЖКХ Кировский")
Прибор: КМ-5/АТ-Т Заводской номер: 362191
Точка измерения: ТВ1; Ресурс: ТС

Подача:
Обратка:
Холодная вода:
Схема измерений: КМ-5-2

Счетчик воды:
ППС-5 SN 362191
ППС-5 SN 362090

Датчик давления:
Коммуналец СДВ-И SN A819155
Коммуналец СДВ-И SN A819156

Датчик температуры:
КТС-Б SN 1331414г
КТС-Б SN 1331414х

Дата	t1	t2	dt	V1	V2	V3	M1	M2	%	P1	P2	Qот	ta	Tr	NS
	°C	°C	°C	м3	м3	м3	т	т	т	атм	атм	Гкал	°C	ч	
01.03.2026	63.64	49.04	14.59	213.76	214.19	0.00	209.76	211.77	-0.95	0.02	3.98	3.04	-60.00	24.00	
02.03.2026	62.39	48.28	14.11	212.28	212.82	0.00	208.47	210.47	-0.95	0.02	4.00	2.92	-60.00	24.00	
03.03.2026	65.57	50.23	15.34	213.79	214.15	0.00	209.56	211.62	-0.98	0.02	4.04	3.19	-60.00	24.00	
04.03.2026	66.90	50.77	16.14	211.31	211.55	0.00	206.97	208.99	-0.97	0.02	4.02	3.32	-60.00	24.00	
05.03.2026	68.92	52.18	16.74	213.93	214.07	0.00	209.30	211.35	-0.97	0.02	4.01	3.48	-60.00	24.00	
06.03.2026	68.50	51.80	16.70	211.64	211.80	0.00	207.12	209.14	-0.97	0.02	4.00	3.44	-60.00	24.00	
07.03.2026	67.03	51.17	15.85	213.75	214.03	0.00	209.36	211.40	-0.97	0.02	3.98	3.30	-60.00	24.00	
08.03.2026	67.45	51.16	16.29	211.45	211.69	0.00	207.05	209.10	-0.99	0.02	4.00	3.35	-60.00	24.00	
09.03.2026	71.66	53.29	18.36	214.13	214.04	0.00	209.16	211.21	-0.98	0.02	4.05	3.82	-60.00	24.00	
10.03.2026	71.63	53.31	18.33	211.85	211.74	0.00	206.94	208.94	-0.96	0.02	4.00	3.77	-60.00	24.00	
11.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
12.03.2026	50.81	41.15	9.66	209.76	210.84	0.00	207.18	209.13	-0.93	0.02	3.83	1.98	-60.00	24.00	
13.03.2026	49.03	40.15	8.87	211.59	212.79	0.00	209.17	211.14	-0.94	0.01	3.88	1.84	-60.00	24.00	
14.03.2026	47.14	39.10	8.04	209.24	210.51	0.00	207.02	208.95	-0.93	0.01	3.86	1.64	-60.00	24.00	
15.03.2026	46.20	38.62	7.58	210.89	212.21	0.00	208.74	210.69	-0.93	0.01	3.83	1.56	-60.00	24.00	
16.03.2026	48.35	40.07	8.28	209.48	210.69	0.00	207.14	209.06	-0.92	0.02	3.78	1.70	-60.00	24.00	
17.03.2026	47.13	39.44	7.69	210.87	212.18	0.00	208.63	210.59	-0.93	0.02	3.69	1.59	-60.00	24.00	
18.03.2026	48.30	40.08	8.22	209.43	210.64	0.00	207.11	209.01	-0.92	0.02	3.52	1.69	-60.00	24.00	
19.03.2026	48.34	40.35	7.99	210.95	212.19	0.00	208.60	210.53	-0.92	0.02	3.67	1.65	-60.00	24.00	
20.03.2026	47.29	39.76	7.53	212.93	214.22	0.00	210.65	212.59	-0.92	0.02	3.55	1.57	-60.00	23.90	
21.03.2026	46.64	39.11	7.53	211.30	212.54	0.00	209.10	210.98	-0.90	0.02	3.71	1.56	-60.00	24.00	
22.03.2026	46.67	39.09	7.58	209.69	210.93	0.00	207.50	209.37	-0.90	0.01	3.73	1.55	-60.00	24.00	
23.03.2026	46.28	38.90	7.38	211.09	212.36	0.00	208.93	210.81	-0.90	0.01	3.73	1.52	-60.00	24.00	
24.03.2026	44.72	37.95	6.77	209.29	210.59	0.00	207.28	209.13	-0.89	0.01	3.69	1.39	-60.00	24.00	
25.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
26.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
27.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
28.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
29.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
30.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
31.03.2026	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	56.11	44.57	11.55	---	---	---	---	---	-0.94	0.02	3.85	---	-60.00	---	
Итого:	---	---	---	4864.40	4882.77	0.00	4790.73	4835.97	---	---	---	54.88	---	551.90	

Дата	V1	V2	V3	M1	M2	Qот	Tr
	м3	м3	м3	т	т	Гкал	ч
28.02.2026	14723.92	14739.22	0.00	14419.16	14547.44	206.12	1413.75
24.03.2026	19801.45	19835.72	0.00	19419.42	19594.92	263.75	1989.65
Итого:	5077.53	5096.50	0.00	5000.26	5047.48	57.64	575.90

Представитель абонента

Представитель энергоснабжающей организации