

Отчет о суточных параметрах ГВС
(01.07.2026 0:00:00 - 31.07.2026 0:00:00)

Объект: Пермский край, Пермь г, Каляева ул, д. 14 (4 МКД УК "ЖКХ Кировский")
Прибор: ИМ2300 А-Е Заводской номер: DB522
Точка измерения: Узел 1; Ресурс: ГВС

Схема измерений: Теплосчетчик с ЧД расхода для ОСТ

Дата	T1 °C	T2 °C	dt °C	Qo1 м3/ч	Qo2 м3/ч	Gm1 т	Gm2 т	dGm т	Qt1 Гкал	Qt2 Гкал	dQt Гкал	tm1 ч	ts1 ч
01.07.2026	61.00	0.00	61.00	0.40	0.00	9.40	0.00	0.00	0.531	0.000	0.000	24.0	24.0
02.07.2026	62.01	0.00	62.01	0.40	0.00	9.43	0.00	0.00	0.546	0.000	0.000	24.0	24.0
03.07.2026	61.70	0.00	61.70	0.35	0.00	8.18	0.00	0.00	0.477	0.000	0.000	24.0	24.0
04.07.2026	63.24	0.00	63.24	0.38	0.00	8.83	0.00	0.00	0.522	0.000	0.000	24.0	24.0
05.07.2026	63.51	0.00	63.51	0.37	0.00	8.67	0.00	0.00	0.513	0.000	0.000	24.0	24.0
06.07.2026	62.47	0.00	62.47	0.37	0.00	8.73	0.00	0.00	0.510	0.000	0.000	24.0	24.0
07.07.2026	63.35	0.00	63.35	0.35	0.00	8.19	0.00	0.00	0.488	0.000	0.000	24.0	24.0
08.07.2026	62.47	0.00	62.47	0.40	0.00	9.42	0.00	0.00	0.548	0.000	0.000	24.0	24.0
09.07.2026	63.21	0.00	63.21	0.39	0.00	9.20	0.00	0.00	0.544	0.000	0.000	24.0	24.0
10.07.2026	62.12	0.00	62.12	0.36	0.00	8.44	0.00	0.00	0.493	0.000	0.000	24.0	24.0
11.07.2026	61.66	0.00	61.66	0.36	0.00	8.49	0.00	0.00	0.489	0.000	0.000	24.0	24.0
12.07.2026	61.91	0.00	61.91	0.39	0.00	9.30	0.00	0.00	0.532	0.000	0.000	24.0	24.0
13.07.2026	61.51	0.00	61.51	0.42	0.00	9.84	0.00	0.00	0.560	0.000	0.000	24.0	24.0
14.07.2026	61.39	0.00	61.39	0.37	0.00	8.62	0.00	0.00	0.501	0.000	0.000	24.0	24.0
15.07.2026	62.24	0.00	62.24	0.38	0.00	8.97	0.00	0.00	0.525	0.000	0.000	24.0	24.0
16.07.2026	61.91	0.00	61.91	0.36	0.00	8.39	0.00	0.00	0.485	0.000	0.000	24.0	24.0
17.07.2026	59.66	0.00	59.66	0.39	0.00	9.11	0.00	0.00	0.509	0.000	0.000	24.0	24.0
18.07.2026	59.70	0.00	59.70	0.38	0.00	8.86	0.00	0.00	0.493	0.000	0.000	24.0	24.0
19.07.2026	59.53	0.00	59.53	0.38	0.00	8.86	0.00	0.00	0.497	0.000	0.000	24.0	24.0
20.07.2026	60.68	0.00	60.68	0.40	0.00	9.52	0.00	0.00	0.539	0.000	0.000	24.0	24.0
21.07.2026	62.03	0.00	62.03	0.41	0.00	9.59	0.00	0.00	0.556	0.000	0.000	24.0	24.0
22.07.2026	61.64	0.00	61.64	0.39	0.00	9.19	0.00	0.00	0.532	0.000	0.000	24.0	24.0
23.07.2026	61.96	0.00	61.96	0.38	0.00	8.85	0.00	0.00	0.514	0.000	0.000	24.0	24.0
24.07.2026	62.83	0.00	62.83	0.35	0.00	8.24	0.00	0.00	0.486	0.000	0.000	24.0	24.0
25.07.2026	63.12	0.00	63.12	0.32	0.00	7.63	0.00	0.00	0.447	0.000	0.000	24.0	24.0
26.07.2026	62.76	0.00	62.76	0.30	0.00	7.16	0.00	0.00	0.417	0.000	0.000	24.0	24.0
27.07.2026	62.71	0.00	62.71	0.30	0.00	7.16	0.00	0.00	0.420	0.000	0.000	24.0	24.0
28.07.2026	63.80	0.00	63.80	0.34	0.00	7.94	0.00	0.00	0.469	0.000	0.000	24.0	24.0
29.07.2026	62.09	0.00	62.09	0.32	0.00	7.48	0.00	0.00	0.432	0.000	0.000	24.0	24.0
30.07.2026	60.94	0.00	60.94	0.37	0.00	8.68	0.00	0.00	0.495	0.000	0.000	24.0	24.0
31.07.2026	38.57	0.00	38.57	0.14	0.00	3.37	0.00	0.00	0.171	0.000	0.000	24.0	24.0
Средние:	61.22	0.00	61.22	0.36	0.00	---	---	---	---	---	---	---	---
Итого:	---	---	---	---	---	263.76	0.00	0.00	15.240	0.000	0.000	744.0	744.0

Дата	Gm_itog1 т	Gm_itog2 т	dGm_itog т	Qt_itog1 Гкал	Qt_itog2 Гкал	dQt_itog Гкал	tm1_itog ч	ts1_itog ч
30.06.2026	10569.16	0.00	0.00	597.064	0.000	0.000	26184.6	26185.0
31.07.2026	10832.92	0.00	0.00	612.304	0.000	0.000	26928.6	26929.0
Итого:	263.76	0.00	0.00	15.240	0.000	0.000	744.0	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.07.2026 0:00:00 - 31.07.2026 0:00:00)

Объект: Пермский край, Пермь г, Каляева ул, д. 14 (4 МКД УК "ЖКХ Кировский")
Прибор: ИМ2300 А-Е Заводской номер: ВВ280
Точка измерения: Узел 1; Ресурс: ТС

Поддача:

Обратка:

Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:

ПРИМ SN 322046

ПРИМ SN 322947

Датчик температуры:

КТПТР-01 SN 10507

КТПТР-01 SN 10507 А

Дата	T1	T2	dt	Qo1	Qo2	Gm1	Gm2	%	P1	P2	Qt1	tm1	ts1
	°C	°C	°C	м3/ч	м3/ч	т	т		МПа	МПа	Гкал	ч	ч
01.07.2026	26.80	26.63	0.16	0.14	0.02	0.16	0.00	200.00	-0.40	-0.40	0.000	1.0	24.0
02.07.2026	27.49	27.26	0.24	0.16	0.03	3.54	0.00	200.00	-0.40	-0.40	0.001	22.5	24.0
03.07.2026	27.73	27.46	0.27	0.16	0.03	3.88	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
04.07.2026	28.01	27.80	0.21	0.15	0.02	3.41	0.00	200.00	-0.40	-0.40	0.001	22.0	24.0
05.07.2026	28.58	28.38	0.20	0.16	0.02	3.73	0.00	200.00	-0.40	-0.40	0.001	23.7	24.0
06.07.2026	28.96	28.81	0.15	0.16	0.02	3.44	0.00	200.00	-0.40	-0.40	0.001	22.0	24.0
07.07.2026	29.40	29.18	0.22	0.16	0.02	3.54	0.00	200.00	-0.40	-0.40	0.001	22.7	24.0
08.07.2026	29.59	29.35	0.24	0.17	0.02	3.97	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
09.07.2026	29.76	29.52	0.24	0.17	0.02	3.98	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
10.07.2026	29.79	29.55	0.24	0.16	0.02	3.79	0.00	200.00	-0.40	-0.40	0.001	23.9	24.0
11.07.2026	29.67	29.43	0.24	0.17	0.02	3.95	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
12.07.2026	29.67	29.43	0.25	0.17	0.02	4.12	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
13.07.2026	29.61	29.33	0.28	0.19	0.02	4.55	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
14.07.2026	29.32	29.08	0.24	0.19	0.02	4.50	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
15.07.2026	29.39	29.13	0.26	0.19	0.02	4.44	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
16.07.2026	29.24	28.94	0.30	0.18	0.01	4.24	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
17.07.2026	28.70	28.48	0.22	0.18	0.01	4.22	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
18.07.2026	28.16	27.95	0.21	0.17	0.01	4.14	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
19.07.2026	27.56	27.34	0.22	0.17	0.00	4.02	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
20.07.2026	27.64	27.50	0.14	0.17	0.01	4.13	0.00	200.00	-0.40	-0.40	0.001	23.5	24.0
21.07.2026	28.36	28.23	0.14	0.19	0.00	4.54	0.00	200.00	-0.40	-0.40	0.001	23.9	24.0
22.07.2026	29.12	28.94	0.18	0.20	0.00	4.77	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
23.07.2026	29.71	29.53	0.18	0.21	0.00	4.99	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
24.07.2026	30.21	29.99	0.22	0.22	0.01	5.15	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
25.07.2026	30.64	30.38	0.25	0.22	0.00	5.28	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
26.07.2026	30.93	30.69	0.25	0.23	0.00	5.58	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
27.07.2026	31.23	31.01	0.23	0.24	0.00	5.85	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
28.07.2026	31.67	31.44	0.23	0.25	0.01	6.05	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
29.07.2026	31.87	31.65	0.22	0.26	0.01	6.10	0.00	200.00	-0.40	-0.40	0.001	24.0	24.0
30.07.2026	31.37	31.07	0.30	0.25	0.00	5.98	0.00	200.00	-0.40	-0.40	0.002	24.0	24.0
31.07.2026	30.45	30.22	0.23	0.22	0.00	5.29	0.00	200.00	-0.40	-0.40	0.001	23.9	24.0
Средние:	29.37	29.15	0.22	0.19	0.01	---	---	200.00	-0.40	-0.40	---	---	---
Итого:	---	---	---	---	---	135.34	0.00	---	---	---	0.031	712.8	744.0

Дата	Gm_itog1	Gm_itog2	Qt_itog1	tm1_itog	ts1_itog
	т	т	Гкал	ч	ч
30.06.2026	53549.27	55466.32	1743.585	14428.4	22016.5
31.07.2026	53684.61	55466.32	1743.615	15141.3	22760.4
Итого:	135.34	0.00	0.031	712.8	744.0

Представитель абонента

Представитель энергоснабжающей организации