

Отчет о суточных параметрах ГВС
(01.10.2023 0:00:00 - 31.10.2023 0:00:00)

Объект: Пермь г, Каляева ул, д. 14 (4 МКД УК "ЖКХ Кировский")
Прибор: ИМ2300 А-Е Заводской номер: DB522
Точка измерения: Узел 1; Ресурс: ГВС

Схема измерений: Теплосчетчик с ЧД расхода для ОСТ

Дата	T1 °C	T2 °C	dt °C	Qo1 м3/ч	Qo2 м3/ч	Gm1 т	Gm2 т	dGm т	Qt1 Гкал	Qt2 Гкал	dQt Гкал	tm1 ч	ts1 ч
01.10.2023	60.30	0.00	60.30	0.41	0.00	9.78	0.00	0.00	0.544	0.000	0.000	24.0	24.0
02.10.2023	59.52	0.00	59.52	0.48	0.00	11.33	0.00	0.00	0.623	0.000	0.000	24.0	24.0
03.10.2023	58.50	0.00	58.50	0.44	0.00	10.45	0.00	0.00	0.560	0.000	0.000	24.0	24.0
04.10.2023	57.71	0.00	57.71	0.47	0.00	11.05	0.00	0.00	0.587	0.000	0.000	24.0	24.0
05.10.2023	59.12	0.00	59.12	0.48	0.00	11.31	0.00	0.00	0.614	0.000	0.000	24.0	24.0
06.10.2023	58.93	0.00	58.93	0.45	0.00	10.61	0.00	0.00	0.577	0.000	0.000	24.0	24.0
07.10.2023	59.57	0.00	59.57	0.40	0.00	9.36	0.00	0.00	0.515	0.000	0.000	24.0	24.0
08.10.2023	57.28	0.00	57.28	0.48	0.00	11.35	0.00	0.00	0.608	0.000	0.000	24.0	24.0
09.10.2023	59.35	0.00	59.35	0.51	0.00	12.12	0.00	0.00	0.662	0.000	0.000	24.0	24.0
10.10.2023	57.56	0.00	57.56	0.51	0.00	12.04	0.00	0.00	0.627	0.000	0.000	24.0	24.0
11.10.2023	55.49	0.00	55.49	0.48	0.00	11.35	0.00	0.00	0.573	0.000	0.000	24.0	24.0
12.10.2023	56.35	0.00	56.35	0.47	0.00	11.04	0.00	0.00	0.567	0.000	0.000	24.0	24.0
13.10.2023	56.26	0.00	56.26	0.46	0.00	10.79	0.00	0.00	0.554	0.000	0.000	24.0	24.0
14.10.2023	57.06	0.00	57.06	0.43	0.00	10.18	0.00	0.00	0.537	0.000	0.000	24.0	24.0
15.10.2023	58.08	0.00	58.08	0.55	0.00	12.90	0.00	0.00	0.692	0.000	0.000	24.0	24.0
16.10.2023	58.26	0.00	58.26	0.49	0.00	11.59	0.00	0.00	0.620	0.000	0.000	24.0	24.0
17.10.2023	60.65	0.00	60.65	0.47	0.00	11.01	0.00	0.00	0.613	0.000	0.000	24.0	24.0
18.10.2023	60.15	0.00	60.15	0.49	0.00	11.49	0.00	0.00	0.635	0.000	0.000	24.0	24.0
19.10.2023	58.18	0.00	58.18	0.45	0.00	10.52	0.00	0.00	0.561	0.000	0.000	24.0	24.0
20.10.2023	58.12	0.00	58.12	0.45	0.00	10.75	0.00	0.00	0.574	0.000	0.000	24.0	24.0
21.10.2023	58.95	0.00	58.95	0.46	0.00	10.97	0.00	0.00	0.594	0.000	0.000	24.0	24.0
22.10.2023	56.38	0.00	56.38	0.43	0.00	10.26	0.00	0.00	0.533	0.000	0.000	24.0	24.0
23.10.2023	56.71	0.00	56.71	0.57	0.00	13.57	0.00	0.00	0.700	0.000	0.000	24.0	24.0
24.10.2023	56.33	0.00	56.33	0.56	0.00	13.14	0.00	0.00	0.675	0.000	0.000	24.0	24.0
25.10.2023	56.29	0.00	56.29	0.51	0.00	12.02	0.00	0.00	0.607	0.000	0.000	24.0	24.0
26.10.2023	59.63	0.00	59.63	0.47	0.00	11.16	0.00	0.00	0.622	0.000	0.000	24.0	24.0
27.10.2023	61.91	0.00	61.91	0.52	0.00	12.27	0.00	0.00	0.696	0.000	0.000	24.0	24.0
28.10.2023	62.53	0.00	62.53	0.50	0.00	11.79	0.00	0.00	0.683	0.000	0.000	24.0	24.0
29.10.2023	61.89	0.00	61.89	0.49	0.00	11.49	0.00	0.00	0.665	0.000	0.000	24.0	24.0
30.10.2023	58.66	0.00	58.66	0.54	0.00	12.64	0.00	0.00	0.676	0.000	0.000	24.0	24.0
31.10.2023	59.29	0.00	59.29	0.50	0.00	11.86	0.00	0.00	0.646	0.000	0.000	24.0	24.0
Средние:	58.55	0.00	58.55	0.48	0.00	---	---	---	---	---	---	---	---
Итого:	---	---	---	---	---	352.18	0.00	0.00	18.938	0.000	0.000	744.0	744.0

Дата	Gm_itog1 т	Gm_itog2 т	dGm_itog т	Qt_itog1 Гкал	Qt_itog2 Гкал	dQt_itog Гкал	tm1_itog ч	ts1_itog ч
30.09.2023	677.15	0.00	0.00	37.160	0.000	0.000	2194.2	2194.6
31.10.2023	1029.32	0.00	0.00	56.099	0.000	0.000	2938.2	2938.6
Итого:	352.18	0.00	0.00	18.938	0.000	0.000	744.0	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.10.2023 0:00:00 - 31.10.2023 0:00:00)

Объект: Пермь г, Каляева ул, д. 14 (4 МКД УК "ЖКХ Кировский")
Прибор: ИМ2300 А-Е Заводской номер: ВВ280
Точка измерения: Узел 1; Ресурс: ТС

Поддача:

Обратка:

Схема измерений: Теплосчетчик с ЧД расхода (ЗСТ)

Счетчик воды:

ПРИМ SN 322046

ПРИМ SN 322947

Датчик температуры:

КТПТР-01 SN 10507

КТПТР-01 SN 10507 А

Дата	T1	T2	dt	Qo1	Qo2	Gm1	Gm2	%	P1	P2	Qt1	tm1	ts1
	°C	°C	°C	м3/ч	м3/ч	т	т		МПа	МПа	Гкал	ч	ч
01.10.2023	66.73	41.43	25.30	3.68	3.63	86.60	86.48	0.14	-0.40	-0.40	2.187	24.0	24.0
02.10.2023	66.16	41.19	24.97	3.69	3.64	86.84	86.67	0.20	-0.40	-0.40	2.165	24.0	24.0
03.10.2023	64.57	40.53	24.04	3.55	3.50	83.65	83.32	0.39	-0.40	-0.40	2.006	24.0	24.0
04.10.2023	63.92	39.62	24.30	3.40	3.35	80.18	79.70	0.60	-0.40	-0.40	1.945	24.0	24.0
05.10.2023	65.50	40.07	25.43	3.51	3.45	82.59	82.08	0.62	-0.40	-0.40	2.097	24.0	24.0
06.10.2023	65.75	40.82	24.93	3.57	3.52	84.00	83.81	0.23	-0.40	-0.40	2.091	24.0	24.0
07.10.2023	66.09	40.77	25.31	3.59	3.52	84.51	83.89	0.73	-0.40	-0.40	2.136	24.0	24.0
08.10.2023	63.08	40.38	22.69	3.89	3.84	91.67	91.36	0.35	-0.40	-0.40	2.100	23.4	24.0
09.10.2023	66.22	42.67	23.55	4.26	4.20	100.13	99.87	0.27	-0.40	-0.40	2.354	24.0	24.0
10.10.2023	64.81	41.54	23.27	4.19	4.13	98.62	98.21	0.42	-0.40	-0.40	2.290	24.0	24.0
11.10.2023	63.41	39.36	24.04	3.68	3.63	86.75	86.41	0.40	-0.40	-0.40	2.081	24.0	24.0
12.10.2023	64.15	40.05	24.10	3.81	3.76	89.81	89.59	0.25	-0.40	-0.40	2.161	24.0	24.0
13.10.2023	64.22	38.79	25.44	3.47	3.42	81.73	81.55	0.22	-0.40	-0.40	2.073	24.0	24.0
14.10.2023	65.37	39.03	26.34	3.40	3.36	80.03	79.94	0.11	-0.40	-0.40	2.105	24.0	24.0
15.10.2023	66.03	39.13	26.90	3.39	3.34	79.69	79.67	0.02	-0.40	-0.40	2.141	24.0	24.0
16.10.2023	67.15	37.84	29.31	2.94	2.91	69.17	69.34	-0.24	-0.40	-0.40	1.981	24.0	24.0
17.10.2023	68.15	42.05	26.10	3.76	3.71	88.30	88.23	0.08	-0.40	-0.40	2.301	24.0	24.0
18.10.2023	67.73	41.90	25.83	3.70	3.65	87.04	86.95	0.10	-0.40	-0.40	2.244	24.0	24.0
19.10.2023	66.27	39.91	26.36	3.39	3.35	79.74	79.88	-0.17	-0.40	-0.40	2.099	24.0	24.0
20.10.2023	66.27	39.17	27.10	3.32	3.29	78.16	78.29	-0.17	-0.40	-0.40	2.115	24.0	24.0
21.10.2023	66.89	39.73	27.16	3.40	3.37	80.04	80.21	-0.21	-0.40	-0.40	2.171	24.0	24.0
22.10.2023	64.87	38.20	26.67	3.25	3.21	76.41	76.39	0.03	-0.40	-0.40	2.037	24.0	24.0
23.10.2023	65.26	37.52	27.75	3.19	3.15	75.18	75.20	-0.04	-0.40	-0.40	2.083	24.0	24.0
24.10.2023	64.87	37.24	27.63	3.19	3.15	75.00	75.02	-0.02	-0.40	-0.40	2.069	24.0	24.0
25.10.2023	64.51	37.45	27.06	3.23	3.19	76.12	76.10	0.03	-0.40	-0.40	2.058	24.0	24.0
26.10.2023	68.10	39.01	29.09	3.46	3.42	81.32	81.59	-0.33	-0.40	-0.40	2.365	24.0	24.0
27.10.2023	70.77	41.10	29.67	3.72	3.67	87.21	87.47	-0.31	-0.40	-0.40	2.584	24.0	24.0
28.10.2023	71.50	41.81	29.70	3.84	3.80	90.16	90.36	-0.23	-0.40	-0.40	2.672	24.0	24.0
29.10.2023	71.72	41.68	30.03	3.80	3.74	89.00	89.05	-0.05	-0.40	-0.40	2.671	24.0	24.0
30.10.2023	69.12	41.19	27.93	3.81	3.75	89.44	89.17	0.31	-0.40	-0.40	2.496	24.0	24.0
31.10.2023	---	---	---	---	---	---	---	---	---	---	---	---	---
Средние:	66.31	40.04	26.27	3.57	3.52	---	---	0.12	-0.40	-0.40	---	---	---
Итого:	---	---	---	---	---	2519.09	2515.78	---	---	---	65.876	719.4	720.0

Дата	Gm_itog1	Gm_itog2	Qt_itog1	tm1_itog	ts1_itog
	т	т	Гкал	ч	ч
30.09.2023	75916.88	75037.84	2380.190	20223.9	33618.9
30.10.2023	78435.96	77553.62	2446.067	20943.2	34338.9
Итого:	2519.09	2515.77	65.876	719.4	720.0

Представитель абонента

Представитель энергоснабжающей организации